



## NOTES:

- 1. APRON SHALL BE CONSTRUCTED A MINIMUM OF 18 FEET FROM THE EDGE OF ROAD.
- 2. PAVEMENT SECTION TO BE 7 INCHES THICK NON-REINFORCED CONCRETE MDOT SHA MIX NO. 9 OR 1.5 INCHES HOT MIX SUPERPAVE 9.5 MM FOR SURFACE (PG 64S-22, LEVEL 1), 3.0 INCHES HOT MIX SUPERPAVE 19.0 MM FOR BASE (PG 64S-22, LEVEL 1), AND 6.0 INCHES GRADED AGGREGATE BASE (GAB).
- 3. COUNTY APPROVAL REQUIRED FOR ANY DESIGN MODIFICATIONS TO THIS DETAIL.
- 4. SWALE APRONS MAY BE USED ONLY WHERE UPGRADE DRAINAGE AREA IS 1-3 ACRES OR DISTANCE TO THE CREST OF HILL IS LESS THAN 150 FEET.

CARROLL COUNTY, MARYLAND  DEPARTMENT OF PLANNING AND  LAND MANAGEMENT		IN COMMON DRIVEWAY APRON WITH SWALE	UIC 7
ISSUED:		REVISED:	
REVISED:		REVISED:	